Techno India NJR Institute of Technology, Udaipur

NAAC

7.1.2

The Institution has facilities for alternate sources of energy and energy conservation measures



50 KW ON-Grid Solar Plant at Techno India NJR







BY: Rajkumar Soni
Assistant Professor
Techno India NJR Institute of
Technology

Table of Content:

- Chapter 1: Glossary
- Chapter 2: Introduction
- Chapter 3: Project Summary
- Chapter 4: Selection Of PV Technology
- Chapter 5: Solar Panel Connections
- Chapter 6: Solar Panel Mounting Structure
- Chapter 7: Grid-Tied Solar Inverter
- Chapter 8: SPV Monitoring System
- Chapter 9: Earthing
- Chapter 10: Net Meter



Chapter 1 Glossary

Photovoltaic	The physical effect of direct Conversion of light (sunlight) to electrical energy	
PV Cell	The smallest photovoltaic (PV) element that generates electricity from light.	
PV Module	A collection of interconnected PV cells, encapsulated between protective materials such as glass and back sheet (Poly Vinyl Fluoride) or glass and glass, and mounted in an aluminum frame. This is a hermetically sealed unit.	
String	Multiple PV modules connected in series electrically	
Array	Several strings of modules with the same orientation and tilt angle, located together.	
Inverter	An electronic device that converts direct current electricity into alternating current electricity suitable for feeding directly into the electrical grid or to normal AC loads.	
Insolation	It is a measure of solar radiation energy received on a given surface area in a given time. It is commonly expressed as average irradiance in watts per square meter (W/m²) or kilowatt-hours per square meter per day (kWh/(m²·day)) (or hours/day)	
Solar	The total electromagnetic radiation emitted by the Sun	
Irradiation		
STC	"Standard Test Conditions" - Incident Solar Irradiance of 1000 Watts/m2, at a spectral density of AM1.5 and cell temperature of 25°C	
Mounting Structure	Device used to hold modules in place, at desired angle & direction	
Power Evacuation	Power generated from Solar PV Power Plant is transmitted to a point (substation) where it is distributed for consumer use.	

Sub-station	The place where the generated power from solar is synchronized with utility grid and metered.	
Efficiency	The ratio of the output to the input of any system.	
Junction boxes	Inputs of several strings are connected to this box and taken as single output	
Current	A flow of electricity through a conductor measured in Amps.	
Voltage	The rate at which energy is drawn from a source that produces a flow of electricity in a circuit; expressed in volts It is the difference of electrical potential between two points of an electrical or electronic circuit, expressed in volts. It is the measurement of the potential for an electric field to cause an electric current in an electrical conductor.	
Lightning Arrestor	Device used to protect all the components from lightning strikes	
Earthing	Described as a systemof electrical connections to the general mass of earth	
Transformer	An electrical device by which alternating current of one voltage is changed to another voltage	
Grid	A system of high/low tension cables by which electrical power is distributed throughout a region	




Chapter 2 Introduction

SECI has been entrusted by MNRE for implementation of a Large-scale Grid connected Rooftop pilot projects, with 30% subsidy support from National Clean Energy Fund (NCEF). This program is being successfully implemented across 16 big and small cities, and projects for around 19.00 MW have been sanctioned in 3 phases.

Installation of 50 KW Grid-Tied Solar Rooftop Plant at Techno India NJR Institute of Technology. It occupies total rooftop space is 1080 square meter. A total load of college is approximate 120 KW and 50 KW of power sending back to grid or RSEB (Rajasthan State Electricity Board) from the Solar plant in form of renewable energy.

In grid-connected rooftop or small SPV system, the DC power generated from SPV panel is converted to AC power using power conditioning unit and is fed to the grid either of 33 kV/11 kV three phase lines or of 440/220 Volt three/single phase line depending on the capacity of the system installed at institution/commercial establishment or residential complex and the regulatory framework specified for respective States.

These systems generate power during the day time which is utilized fully by powering captive loads and feed excess power to the grid as long as the grid is available. In case, where solar power is not sufficient due to cloud cover etc., the captive loads are served by drawing power from the grid.




A total number of solar panels is 170 and two grid-tied type inverters each is 25 KW. Connections of all solar panel are in the manner of that 17 panels are connected in series, this is one string of 17 panels and we have 5 strings, which makes a total number of the panel is 85.

(17 panels in series) * (5 strings) = 85 panels

The output of all 5 strings goes to one 25 KW inverter. As it is the other output of remaining 5 strings goes to another 25 KW inverter.

The single line diagram of the plant shown below:



As shown in SLD (Single Line Diagram) There are two SPV (Solar Photovoltaic) arrays each containing 85 solar panels going to two set of inverters each of 25 KW rating after than output of each inverter which is in form of Alternating Current (AC) are combining in the MJB1 (main junction box) with protecting of 50 A rating of MCBs. C1, C2, C3 and C4 are types of cables used.



All ratings and specification of each equipment are shown below:

Sr. No.	Ratings/ Specifications	
1.	SPY Array 1: 300Wp- 85 Nos. – 17X5 Strings 1Nos.	
2.	SPY Array 2: 300Wp- 85 Nos. – 17X5 Strings 1Nos.	
3.	Inverter 1: INVT, 25 KW X 1Nos.	
4.	Inverter 1: INVT, 25 KW X 1Nos.	
5.	MJB 1: MCB -1 (4P, 50 Amp-1Nos.)	
6.	MCB -2 (4P, 50 Amp-1Nos.)	
7.	SPD-1 (3 Phase AC, 320V)	
8.	MJB 2: MCCB -1 (4P, 125 Amp-1Nos.)	
9.	C1: 1CX2(R/B) 4sq.mm, CU. Solar Cable	
10.	C2: 4CX10 sq.mm, CU. Cable	
11.	C3: 3.5CX50 sq.mm, AL. Armored Cable	
12.	C4: 3.5CX50 sq.mm, AL. Armored Cable	



Chapter 3 Project Summary

1.	Name of the Company	Techno India NJR Institute of Technology	
2.	Proposed Project Location	RIICO Industrial Area, Kaladwas	
3.	District Name	Udaipur	
4.	State	Rajasthan	
5.	Proposed Power Plant capacity	50KWp	
6.	Technology	Solar Photovoltaic	
7.	Location of place on Earth	(i) Latitude: 24.5176° N (ii) Longitude: 73.7516° E	
8.	Average annual solar isolation	6.16 kWh/m²/day	
9.	Type of Module proposed	Mono Crystalline	
10.	Type of Inverter proposed	String	
11.	Total Inverter capacity	25 KW	



Chapter 4 Selection of PV Technology

Science of Silicon PV Cells

- ➤ Scientific base for solar PV electric power generation is solid-state physics of semiconductors
- ➤ Silicon is a popular candidate material for solar PV cells because:
 - It is a semiconductor material.
 - Technology is well developed to make silicon to be positive (+ve) or negative (-ve) charge-carriers – essential elements for an electric cell or battery
 - Silicon is abundant in supply and relatively inexpensive in production
- ➤ Micro- and nanotechnologies have enhanced the optoelectricity conversion efficiency of silicon solar PV cells



Polycrystalline Solar Panel


Working Principle of Silicon Solar PV Cells


Photovoltaic material of device converts:



Silicon solar photovoltaic cells = a device made of semiconductor materials that produce electricity under light

A p-n junction is created in silicon by a doping process.





Common Solar Cell Materials

Single Crystalline	Polycrystalline (Thin films)	
Silicon (Si): Single crystalline	Cadmium telluride (CdTe)	
Polycrystalline silicon Amorphous silicon (non- crystalline Si for higher light absorption) Gallium arsenide (GaAs)	Copper indium diselenide (CIS)	

Approximate Achievable Conversion Efficiencies

Single Si	15 – 25%	
Poly Si	10 – 15%	
A-Si	5 - 10	

GaAs	25 – 30%	
CdTe	7%	
CIS	10	



Chapter 5 Solar Panel Connections

As for showing in single line diagram, there is one string of 17 panels and we have such 5 strings, which makes a total number of the panel is 85. In one string 17 panels connected in series.



Series connection



Specification of the single solar panel:





According to solar panel electrical ratings:

The Voltage at Max Power (Vmax) is 36V, Current at Max Power (Imax) is 8.48A and Max peak power is 300W. So 17 panels of such ratings connected in series which add up voltages of all panels:

 $17 \times 36 = 612 \text{ V}$ and 8.48 A (because current is common in series)

Finally, this 612 V and 8.48A is the output of one string. Five strings output connected to one 25KW Grid-Tied Inverter.

Connections are showing in fig:





Chapter 6 Solar Panel Mounting Structure



Module mounting structures play a very important role in the efficient working of a solar power plant. While most of the components of balance of system (BOS) such as inverter DC cables junction boxes transformers, etc. are readily bought from the equipment suppliers the workmanship of an EPC contractor is reflected mainly through module mounting structures and wiring management


The Recent installation of a solar project in India has adopted various module mounting structure design which includes the structures made of galvanized iron as well as aluminum structures. Some of the projects have adopted a combination of steel structure and aluminum structure wherein vertical legs are

made off hot dipped galvanized steel and rest of the members are made off extruded aluminum structure. Typically, module mount structure comprises of following components:

- 1. Vertical rail (Rafter)
- 2. Vertical posts
- 3. Purlin (Horizontal rail)
- 4. Tilt bracket
- 5. Mounting clips
- 6. Cable tray

The mounting structure should consider local site conditions such as wind speed, rainfall & temp. While selecting module mounting structures. As the solar plant is expected to be designed for a 25 years lifetime, it is important for a project developer to ensure that the mounting structure remains until the lifetime of the project. Mounting structure life is high effected by corrosion and it is important that structure galvanization should be sufficient to protect it from corrosion. The typical structure galvanization thickness is kept of the order of 100-120 microns. In the case of purlin, the structure can be an old formed steel with a lesser galvanization thickness of the order of 80 microns.





- 1. Module Mounting 'C' Channel-50x72x50x2mm-1600mm Long
- 2. Vertical Support 'C' Channel-50x65x50x2mm-500mm Long
- 3. Support 'L' Clamp
- 4. Aluminum 'T' Clamp
- 5. Base Pipe
- 6. Rcc Base
- 7. Rcc Base Fitting Clamp
- 8. Base Pipe Fitting Clamp

All Dimensions Are In M.M.

Material : M.S (Hot-dip galvanized)

Typically, the vertical posts are of C-section, however recent design use sigma section as well in order to add strength and durability. Some of the structure design use tubular/square section which is good to provide connectivity with a rafter. The

tubular section/ square section allows a U-bolt and saddle connection to hold rafter. The purlin is lighter members in the structure on which modules are mounted. Many structure design use Z section purlins so that the bottom flinch of the Z section can be used for carrying the DC cables along with it. The purlin is typically the rate of 2 mm thickness pre-galvanized sheet to protect the purlin from corrosion. It is advisable to use snake tray to carry DC cables rather than carrying the cable in the purlin the nuts & bolts use to connect structure member should be made of stainless steel in order to avoid corrosion. The modules are mounted on the structure with the help of module clips which is typically design for a panel thickness of about 50 mm. spring loaded hardware allows clips to be installed before the panel is installed. The module structure should be grounded properly and the structure leg should have a provision of grounding stake.

A good structure design can significantly reduce structure weight per MW. It should have an integrated wiring management system so that cables can run through perforated sections it's important to carry out on-site pull-out test in order to decide the structure foundation death.

Many times, the structures are design to accommodate single axis/double axis tracking system which makes the structure design complicated. Mounting of modules of the structure should be done by torque wrenches so that it does not put excessive pressure on modules. Finally, structure design should have adequate provisions to accommodate thermal expansion so that sagging in the structure does not occur.

Chapter 7 Grid-Tied Solar Inverter




A solar grid-tied inverter converts the DC output of PV modules into AC power suitable for transmission on the power grid, or use it for your own consumption, often deploying reactive power to meet new grid codes. It must always optimize the power output via MPPT (maximum power point tracking) and additionally monitor both the system and grid connection. In practice, each solar inverter installed in solar power plants needs to connect an array or string of PV modules to the power grid. e more efficient the inverter, the better the LCOE (leveled Cost of Electricity) generated by the system. An on-grid solar inverter is composed of a DCDC module, a DC-AC module and a control module. DC-DC module is built with a MOSFET, an inductor and a transformer, and functions to provide a stable DC output through rectifying and filtering the unstable DC power produced by PV modules; DC-AC module includes an IGBT array and an output filter circuit to convert the DC output of DCDC module into an AC output suited for transmission on power grid. The control module is the core of the whole system. It has a DSC, a voltage sensor, a current sensor, and a driver that drives MOSFET and IGBT module. DSC calculates the maximum power point of PV module array based on signals collected by sensors including PV modules' voltage and current, power grid's voltage and current, as well as phase. And accordingly, it sends out instructions to the driver which drives DC-DC and DC-AC modules. Furthermore, DSC is able to find out abnormal conditions such as transmission failure of the power grid and take measures such as cutting off the connection between inverters and grid to prevent "island effect "occurrences on the power grid. Additionally, the control module has an interface for

external display showing PV modules' status and input/output voltage and current and integrates an RS232/RS485 communication interface to connect with control centers of solar power plants, so that real-time monitoring of solar panels and inverters can be implemented.





Each inverter is of 25KW rating and converting DC to AC and output of each adding in junction box shown in fig:



How does it work?

PV Grid Connected Inverters operate at a lower, safer voltage from the PV array while having the advantages of reliability,

flexibility and improved energy yield. Using lower voltages on the PV side means there are lower voltages in your roof eliminating high voltage hazards and giving peace of mind to installers and service personnel. By using short multiple strings of panels, PV Grid Connected Inverters make sure that there are more paths for electricity to flow, which ensures minimal power loss due to varying environmental or panel conditions.

ON GRID/GRID TIE SOLUTIONS

String Inverter - Single Phase


1800Wp, 2400Wp, 3300Wp 4600Wp, 5500Wp 12000Wp

Central Inverter - Three Phase

50KWp, 100KWp, 250KWp, 500KWp, 1000KWp



Specification of Inverter:





Chapter 8 SPV Monitoring System



As the name suggests, a monitoring system continuously reviews the critical aspects of a product and reports on the progress of each component. Think of it as an automated, software version of a supervisor. Solar power plants, especially large solar farms, today have sophisticated monitoring systems. These systems enable solar power plant operators to streamline operations and monitor the critical activities on a continuous basis.

Solar monitoring makes certain that your solar panels are working properly by tracking the power output of your system. With solar monitoring, you gain 24/7 peace of mind that your panels are working as efficiently as possible. Importantly, you'll also gain the ability to view how much money your solar system is actually saving you in energy costs. Solar monitoring gives you real-time visibility into the number of kilowatt hours of electricity your solar panels are producing at any given moment in time.

Monitoring solar panel output is a great tool to continually track how well your solar power system is working. It's an easy way to see the amount of energy you've produced and follow the proper power output of your solar panel system. Solar monitoring software allows you to easily view how many kilowatt hours of electricity your solar panels are producing at any given moment in time. In the unlikely event something was to go wrong with your system — a faulty wire or panel, for example — your solar monitoring system will pinpoint the specific issue so that you can resolve the problem quickly and efficiently. Solar monitoring also provides you quick and easy ways to track how much money your solar system is saving you in energy costs.

Solar monitoring can tell you if your panels are working properly and how good of a job they're doing. With solar monitoring, you're able to see how much your system is generating, when it's producing the energy and whether your system is over producing or underproducing. **Monitoring your solar panel output** helps you make the necessary adjustments to be certain your system is working properly. Not only are solar

monitoring systems able to tell you how much energy your panels are currently producing, but they can also keep you informed about many your panels have produced over time, giving you a sense of how much energy and money you've saved.

Chapter 9 Earthing

Basically, there are 3 types of earthing in a solar plant - DC, AC and LA.



AC Earthing:

AC earthing is a standard one as you have in any commercial/Industrial Earthing. The list of earthing will be as follows.

- 1) Earthing for your ACDB Panel
- 2) Earthing for your Transformer and other switchgear panels/equipment's

DC Earthing:



The DC Earthing is done to basically ground the Metallic body of your panel and prevent people from getting electrocuted in case of an accident


Even DC SPD's (Surge Protection Devices) can have a special separate earth for them

Lightning Arrestor:

Lightning Arrestor is a bit complicated.


There are Multiple Methods to do this

1. **Conical Area Coverage:** In this you generally have long pole earthed solidly to ground. The Area covered by this is equal to the conical area formed (45 Degree). The Figure is Self-explanatory But generally, this method causes shading issues!



2. Surrounding by Conductor: In this method, you surround your entire modules by surrounding it by a G.I wire

connected to poles surrounding the entire modules. (Assume the house to be your modules)



Selection of Earthing Techniques: As far as material selection for earthing is concerned it is based upon commercials and site requirements.

Copper is always preferred over G.I. but it is costly as compared to G.I. you can do electrode earthing over conventional plate earthing but again it is a costlier alternative and depends upon site requirements.

Most importantly you have to get your earth resistance below the specified range generally 1 Ohm.

Chemical Earthing that you mentioned includes a special chemical powder that you put in the earth pit instead of conventional salt and Coal. The powder provides a better resistance as compared to salt and coal.



Chapter 10 Net Metering

Rajasthan would probably be the next Gujarat in India in terms of a role model for solar. The irradiation in Rajasthan is in the range of 5.5-6.0 (kWh/m2/day). That's among THE best in India (refer to this map). So, in general, the state is perfectly appropriate to go solar climatically. Further, looking at Rajasthan's solar policy which was revised in 2014 (refer), it is clear that the push for solar is not only through small rooftop plants but also through ground-mounted solar parks that should be developed soon. This article, however, will focus on rooftop solar in Rajasthan.

"Net metering" means methodology under which the electricity generated by the solar rooftop system owned by the consumer and delivered to the Distribution Licensee may be utilized to offset the electricity supplied by the Distribution Licensee to the consumer during the applicable billing period.

Following are the key highlights of the net-metering guidelines (refer) in Rajasthan:

- Released on 26.02.15
- Cumulative capacity allowed at the particular distribution transformer shall not exceed 30% of the transformer capacity
- The distribution licensee will update the capacity available at each distribution transformer, on a yearly basis on their website

- The maximum Rooftop PV solar power plant capacity that can be installed at any eligible consumer premises shall not be more than 80% of the sanctioned connected load.
- Any eligible customer needs to install a minimum of one-kilo watt peak on the rooftop and a maximum of 1 MW

The average commercial tariff for Rajasthan is ₹ 7.4. Excess injected electricity into the grid shall be paid by the distribution licensee at feed-in-tariff as follows in the next billing cycle as long as the export is above 50 units. If the export is below 50 units it shall be adjusted in the next billing cycle at the same tariff as their billing rate.



Table- 8: Summary of Solar PV and Solar Thermal Tariffs

S. No.	Particulars	Tariff (₹/kWh) if AD benefit is not availed	Tariff (₹/kWh) if AD benefit is availed
1	2	3	4
1	Solar Photo Voltaic (PV) Power Plants commissioned by 31.03.2017	6.74	6.10
2	Solar Thermal Power Plants commissioned by 31.03.2018	11.46	10.30
3	Roof Top Solar PV installations and other small solar PV power generation plants to be commissioned by 31.03.2017	6.74	6.10
4	Small Solar Thermal Power generation plants to be commissioned by 31.03.2018	11.46	10.30



Solar Energy:




50 KW Solar Power Plant







4. Smart Meter Sensorbased energy conservation



Smart Meter Sensor-based energy conservation

Key points:

- Problem Statement
- Solution

- Technology Details
 - o IOT
 - o CLOUD

Problem Statement:

There is a need for a viable method for metering and calculating the energy consumption. Innovative software-based solutions that could provide live information related to consumption of electricity by various appliances. Methods for making it more cost-effective.

Solution:

- Eliminates manual meter readings
- Quick and Accurate Detailed Reading
- Real Time Monitoring for Distributors as well as Consumers
- Optimizes income with existing resources


Technology Details:

Cloud Computing: Cloud computing is A model for enabling convenient, on-demand network access to A shared pool of configurable computing resources (E.G., Networks, servers, storage, applications, and services) that can be rapidly provisioned and released with minimal management effort or service provider interaction.


Internet of Things: The internet of things refers to the ever-growing network of physical objects that feature an IP address for internet connectivity, and the communication that occurs between these objects and other internet-enabled devices and systems.

Data Analytics: Data analysis is a process of inspecting, cleansing, transforming, and modeling data with the goal of discovering useful information, informing conclusions, and supporting decision-making.

Use case Diagram:




Dashboard:



Analytics Based on different Parameters:

5. Use of LED bulbs/power efficient equipment:



LED bulbs


in-	1	13012	230 08M, Madr	अजम	विद्युत वितः विद्युत उपभोग विपः पेन नं. AA कार्यानय फोन नं.	1(3	रभोवता प्रति.) १६८२६	प्ता शिकायत कोन्द्र : १12301280189 में 1895/1801886545		
-	भाग		नावादिप वि	नेतेन्द्र रा	75.000.000.000	gan ai	0294-2491526 ZIM SIT REGION	विकासिक विकासिक	(75.)	
ŀ	पता				-11-40	1.	विद्युत खर्च		1420.	
ı		U	जुकेशान चेरित	वल_भी	-	2	स्थाई शुल्ब			
1		एसा	पिंल . बेल्ट	ेल .ब्रेल्टनन रिको		3.	विद्याद्य सरकार्ज विद्याद्य सरकार्ज	2025	20250.00	
ŀ		_	स्ट्रीयल एरिया	Inn. n. n.				town 1		
Ēŀ.	मोबाइलन		8696932800	विलिंग स्थित	REGULAR	4.		-502	5-52	
된	इंग्रेल :					s. अनाधिकृत उपभोग राशि				
라	यो. नंबर:		1301230083				सी.टी./पी.टी./मीटर किराया	900	0.00	
			233			7. ट्रांसफार्मर किराबा				
			8211939	अमानत राशि	226456,00	8.	अन्य	416	3.00	
100	वर्गमान सामा संख्या 0692/0309				9.	रिबंद्स (-) (i) योल्डेज				
nadh.	क्रिल माह Dec/2020		कुल माइ बिल	1.0000		(ii) स्तंलर/स्प्रिक्लर/ग्रामीण रियायत				
	पीडा कोड 11F102310		11F1023107	टैरिफ कोड	2011	10.	निगम राशि (क्रम सं. १ से ९ तक का योग)	109228	5.63	
	स्वी. क्षेणी		NDS			11.	सिद्युत शुल्क वर्तमान उपभोग पर		5.60	
dan.	स्थी. लांड (क्रिक. क्राच्ये.)		120.00 KW	कनेक्टेड लोड (भागा/सध्ये)	120-00 KU	12.	जल संरक्षण क्रस्कर	953		
	सार्थेश्वर विस्थित (सोवियर,)		100	शहरी/ग्रामीण	RURAL	13.	नगरीय अवकर	953.	70	
ř	र्ज थो	-	11000 V	मीटरिंग कोल्टेज	11000 V	14.	अन्य देय/ जमा कोड निगम राशि	-13141	1 70	
	मीटर स्वार्ग	_	-1000 4	भीटरिंग टाइप		15.	अन्य देव ⁄ तमा कोड विदात शुलक	-1314	1.37	
타	पांचर पीखटर		0.962	विक्रिक्त विकास	75,0000	16.	अन्य देव/जमा कोड जल संरक्षण उपकर	_	-	
			16789	मीटर सुरक्षा राजि	1310000	-				
	C-gracia: 7			-	0120	17.	अन्य देय/जमा कोड नगरीय उपकर			
ēŀ.	मोटर की स्थित 🕒 📉		त्रायोक्त की स्थित	R .	18.	अन्य देय/जमा कोड/एल.ई.डी./डेफीड योजना	भ्यतान	_		
Ы.			01-12-2020	गत गढन तिथि	01-11-202	019.	समायोजित गाज़ (कोड)			
라	कांदन स्वक्ति मीटर पं		496145	गुणांक	15/10	20.	कुल उपभोग राज़ि (क्रम्प. मं. 10 से 19 तक का	योग) 10085	4.74	
1	क्रतंत्रका घडन (KWH)		502835	गत पठन (KWH)	496476	21.	पिछले बिल तक बकाया राशि			
ũΙ.	वर्तमा पहन (KVAH) 546020		546020	गत घडन (KVAH)	539411	22.	स्थरित चकाया राशि (चालु माह)			
36	खर्गमान पटन (KVA) 20.6		20.600	गत पठन (KVA)		23.	राज्य सरकार द्वारा वहन राशि - (i) टेरिफ स	थाडी		
ı	महो पर्व अधिक मेरा पं		F-1	गुणांक			(ii) ओला वृष्टि / अन्य सम्मिडी			
	क्षांमान पठन	(KWH)		यत पठन (KWH)		24.	नियत विधि तक देव कुल शक्ति (क्रम. एरं. 20+21-	22-23) 100855	5.00	
	वर्तमान पडन	(KVAH)		यत घटन (KVAH)		25.	वितम्ब भुगतान सरधार्ज	192	1,70	
1	वर्गमान पटा	(KVA)		गत पठन (KVA)		26.	नियत तिथि परम्यात् देव ब्युत राष्ट्रि (क्रम. सं. 24 एवं 25	खयोग) 102776.	.00	
j	(51	स्थिति		दूर. श्रनि	क्नुत उपभोग		पिछले छ: ब्रिलिंग माह मैं अंकित			
ľ	उपभोग	eswee	6359		9539	माह	Nov20 Oct20 Sep20	Aug20 Jul20	Jun2	
Ì		(PHAV20)	6609 9914			अपभोग 15342 24450 22848 26344 22869 256			2562	
l		(KVA)	20.600		30,900	348	शेवना पेन मं. 0			
l	दिल जरी कर	रेकी विकि	08-12-2020	नियत भूगसन सिंह	23-12-202	b	1 0			
	कोड: सोय्ससी	एसं ई-सि	त्र कियोस्क द्वारा जारी मा	त्र कम्प्यूटर अवि		are or	t on 18/12/20	योहर प्रदायमा अर्थ	चिवना	
941	भोक्ता का	नाम		नेतन्द्र र	जमेर विद्युत वित विद्युत अपनेग वि प्राचित		निगम लिमिटेड कार्यालय प्रति.) विला चं. 1: के. मध्य मु 3(301230128 0 18 7		
वा	न माह		Dec/202	0	भुगतान का माध्यम : न	गर/बे	ion vi.	भुगतान प्राप्ति की मोहर है	नु स्थान	
ari	मान खात	संख्या	0692/03	09	नियत भुगतान तिथि		23-12-2020			
	खण्डकाकोड 1301230			नियत भुगतान तिथि तर						

(FIRST)			.9/	विद्युत उपभोग विपः						
	AUUNL	&M. Madri)			ACCA8562E					92745
12.						4-24915	26	टोल फ्री शिका	THE P. 1880	01305565
g	भाग	नावादिप जि	निद्र राण	वत	-	विवरण				बिलगरिश (क
É	एजके	शान चैरिटेवल	फौ		1.	विद्युत खर्च			-	102102
gipt.	एसापि	शान चैरिटेबल िल .बेल्टनन	र रिको		2.	स्थाई शुल्क			-	20250.
TIT DIE		यल एरिया			3.	डिमांड सरचा			_	-
100	मांबाइलर्न.	8696932800	व्यालग स्थित	REGULAR	4.		र्वि(+)ग्रेसान्।	्रे/ शर क्षप्रसर ह	ल्बाने (३%)	-714.7
	इंमेल :		_		5.	अनाधिकृत उ	A100 E 075E-1			
10	को नंबर:	13012300830	7		6.		्रमीटर किराय	r		900.0
age of	RSN:	233			7.	ट्रांसफार्मर वि	लावा			
Ped	संवा ऋग्यंक	8211939	अमानत राशि	226456.00	8.	अन्य				7500.0
8000	वर्तमान खाता संख्या	0692/0309			9,	रिखंद्स(-)	(i) चोल्डेज			
101 100	विल माइ	Jan/2021	कुल माह बिल	1.0000		(ii) स्रोलर/व	स्प्रंक्लर/ग्रामीण	रियायत		
9	फोइर कोड	11F1023107	टेरिफ कोड	2011	10.	निगम राशि (क्रमसं १ से १	तक का योग)		130037.7
and a	स्वी. क्षेणी	NDS			11.	विद्युत शुल्क	वर्तमान उपभोग	घर		4614.8
to de	स्थी, लोड (भिज्ञा-कार्या.)	120.00 KW	क्रमेक्टेड लोड (Reservent)	120.00 KU	12.	ज्ञान संरक्षण :	उपकर			1153.7
15	कांदेश दियाँ (के बि.ए.)	100	शहरी/ग्रामीण	RURAL	13.	मगरीय उपका				
10.00	सप्लाई बोल्टेज	11000 V	मीटरिंग बोल्टेज	11000 V	14.	अन्य देव/ भा	मा कांड निगम र	nf\$r		-1179.8
try d	मोटर स्वामित		मोटरिंग टाइप	TVM	15.	अन्य देव/जा	ग कोड विद्युत :	सुल्का -		
Pare	पांबर फेबटर	0.964	विशिग डिमांड	75.0000	16.	अन्य देव/जा	स कोड जल सं	क्षण उपकर		
1	ओसन मस्तिक ग्राप्येग (गू.सि.स.)	16789	मीटर सुरक्षा राजि		17.	armin on	स कोड नगरीय	THE REAL PROPERTY.		
18	मोटर की स्थित	OK	रायंक्त से विक्र		18		त कोड/एल.डी.	201100		
100	चर्तमान पठन तिथि	01-01-2021	गत गठन तिथि		120	समायंत्रित र		SL/ SVIS NIK	en sprant	
, will be	कांसन स्वापित मीटा न	496145	inis		20.		राशि (क्रम. मं.	10 T 10 THE	neroles)	
d span	व्यांमात पटन (KWH)	510526	মূল মূলে (KV/H)	15/10	21.	-	राश (क्रम. स्ट क वकापा राहि		વા પાગ)	134626.4
19	অৰ্থনাৰ অচৰ (KVAH)	553993	THE SERVICE AND ADDRESS OF THE PERSON NAMED IN COLUMN TWO IN COLUMN TO THE PERSON NAMED IN COLUM	546020	22.		या राशि (चाल्		_	
00.15		21.300	यत पड़न (KVA)	340020	23.		द्वारा यहन राहि		nfarê	
24.5	सानं गर्वः अस्तिका सेटा नं	21.300	गुगांक		25.		दि/ अन्य सबि		SA S	
1200	वर्तमान पठन (KWH)		गत पठन (KWH		24.	C. C. C. C.	हा देव बहुल राशि	2001	M 22 22 1	134626.0
Paffey	वर्तमान पटन (KWH)		THE TIESE (KVAH		25.	विलम्ब भूगत		(904L HL 2012	1-22-23)	2577.1
illa.	वर्तमान पटन (KVA)		THE SER (NOVA)		26.	-	हन सर पहल हात् देव कृत गति।	one of a conf	an months >	
a	योजन ५०७ (KVA) मीटर की रिश्चति				26.	_			-	137204.00
		7691	द्रा. क्षति	कुल उपधोग 11537		Dec20	पछले छः विकि Nov20		Sep20	माह जक्योग (सूनि Aug20 Jul
	उपभोग ^(KWH)	7973		11960	माह	-	15342			
	(KVAH)	100000		COLUMN TO SERVICE STATE OF THE	-	9538	15342	24450	22848	26344 228
	-	21.300	Townson or	31.950	30.	रोक्ता पंत मं.	-			
	विल जरी करने की लिंह र कोड:	00-01-2021	ानयत भूगतान तिथि	22-01-2021						

For Techno India NJK Institute en Technology

R.B. Vyas)

Director



August Month Net meter calculation







01

Bill 01 details:

Bill Import: 469948 kWh

01 Bill Export: 9656 kWh

01 Bill Net: 460291 kWh








02

Bill 01 details: Bill Import: 454716 kWh

02 Bill Export: 9577 kWh
02 Bill Net: 445439 kWh



अन्य देय/ जमा कोड निगम राशि

2324.77

Solar generation is adjusted to this section of bill (Fuel Surcharge)

Net metering calculation:

01 Bill Export: 9656 kWh 02 Bill Export: 9577

kWh

Unit calculation formula:

- 1. Difference: 9656 9577 = 79 kWh
- 2. Total Unit Exported to grid: 79 * 1.5 =118 kWh (units)
- 3. Cost of Exported Units: 118 * 8.85 (8.85 Rs. /Unit) = 1048.73 Rs.
- 4. 1048.73 Rs. Adjusted in highlighted section of Bill.
- 5. Total Fuel Surcharge (Debit Rate) of August monthBill: 3373.5 Rs.
- 6. Fuel Surcharge (Debit Rate) Cost of Exported Units (Credit Rate) =3373.5 1048.73 = 2324.77 Rs.



1. Energy Audit

Collection of experimental data:

All required data is collected by the Department of Electrical Engineering. In the building, in every room, how many fans, tube lights, bulbs, computers, instruments AC, etc. will be measured. According to the survey following data is collected.

Table: Total Load During Jun 2023 to Jul 2024

Department/Office	Fan	LED Tube light	A.C.	Fridge	Computer	Printer	Scanner	Xerox Machine	Projector	LED TV
Director Office	2	6	2	0	1	1	0	0	0	0
Principle Office	4	9	2	0	0	1	0	0	0	0
Chemistry Lab	11	16	0	0	0	0	0	0	0	0
Physics Lab	3	6	0	0	1	0	0	0	0	0
Chairperson Room	1	2	1	0	0	0	0	0	0	0
Account Dept	4	2	1	0	3	1	1	3	0	0
Exam Dept	4	5	0	0	2	1	1	1	0	0
Staff Room	18	30	5	0	25	18	5	0	0	0
Library	8	16	0	0	3	1	1	1	0	0
Classrooms	102	216	0	0	7	0	0	0	8	0
Pantry	1	3	0	1	0	0	0	0	0	0
Seminar Hall	8	16	5	0	1	0	0	0	1	0
Wash room	0	18	0	0	0	0	0	0	0	0
Passage	0	60	0	0	0	0	0	0	0	0
Dept Labs	158	256	20	0	424	0	0	0	8	2
I3 Lab	11	21	4	1	11	3	1	0	1	2
Mechanical Workshop	20	30	0	0	1	0	0	0	0	0
Hostel	30	40	0	0	3	0	0	0	0	0
Canteen	15	16	0	3	0	0	0	0	0	0
Main Entrance	6	16	0	0	0	0	0	0	0	0
Gym	12	15	0	0	0	0	0	0	0	1
Visiting Room	1	2	0	0	0	0	0	0	0	1
Parking Area	6	12	0	0	1	0	0	0	0	1
Total Quantity	425	813	40	5	483	26	9	5	18	7
Avg. Wattage rating of single appliance(W)	60 W	25 W	1.5 / 2.0 Ton	1100 W	180 W	100 W	100 W	300 W	220 W	90 W
Average number on at a time	204	510	20	4	220	20	6	4	14	5
Total Wattage on at a time (W)	12240	12750	34500	4400	39600 Techno	India N2000 rechno	es) ·	1200	3080	450
Total maxii	num Po	wer Reg	luiremen	t of all a	ppliances =	21100	110820	Watts		

Table: Total Load During Jun 2023 to Jul 2024

Department/Office	Fan	LED Tube light	A.C.	Fridge	Computer	Printer	Scanner	Xerox Machine	Projector	LED TV
Director Office	2	6	2	0	1	1	0	0	0	0
Principle Office	4	9	2	0	0	1	0	0	0	0
Chemistry Lab	11	16	0	0	0	0	0	0	0	0
Physics Lab	3	6	0	0	1	0	0	0	0	0
Chairperson Room	1	2	1	0	0	0	0	0	0	0
Account Dept	4	2	1	0	3	1	1	3	0	0
Exam Dept	4	5	0	0	2	1	1	1	0	0
Staff Room	18	30	5	0	25	18	5	0	0	0
Library	8	16	0	0	3	1	1	1	0	0
Classrooms	102	216	0	0	7	0	0	0	8	0
Pantry	1	3	0	1	0	0	0	0	0	0
Seminar Hall	8	16	5	0	1	0	0	0	1	0
Wash room	0	18	0	0	0	0	0	0	0	0
Passage	0	60	0	0	0	0	0	0	0	0
Dept Labs	158	256	20	0	424	0	0	0	8	2
I3 Lab	11	21	4	1	11	3	1	0	1	2
Mechanical Workshop	20	30	0	0	1	0	0	0	0	0
Hostel	30	40	0	0	3	0	0	0	0	0
Canteen	15	16	0	3	0	0	0	0	0	0
Main Entrance	6	16	0	0	0	0	0	0	0	0
Gym	12	15	0	0	0	0	0	0	0	1
Visiting Room	1	2	0	0	0	0	0	0	0	1
Parking Area	6	12	0	0	1	0	0	0	0	1
Total Quantity	425	813	40	5	483	26	9	5	18	7
Avg. Wattage rating of single appliance(W)	60 W	25 W	1.5 / 2.0 Ton	1100 W	180 W	100 W	100 W	300 W	220 W	90 W
Average number on at a time	204	510	20	4	220	20	6	4	14	5
Total Wattage on at a time (W)	12240	12750	34500	4400	39600	2000	600	1200	3080	450
Total maxin	mum Po	wer Rec	_l uiremen	t of all a	ppliances =		110820	Watts		

2. Bore-well motor details: 3- phase Induction motor of 5 HP, consumes approx. 8 units per day so monthly around 240 units.

3. Power Consumption of Electricity Board

Table: Power Consumption During June 2023 to July 2024

Sr. No.	Month	Consumption Units (kWh)
1	Jun	22893
2	Jul	21386
3	Aug	19191
4	Sep	16743
5	Oct	19677
6	Nov	16151
7	Dec	22725
8	Jan	14024
9	Feb	11460
10	Mar	10451
11	Apr	11778
12	May	20193
13	Jun	22751
Total Power Consu	mption in Yearly	229423
Average Power Cor Monthly	nsumption in	17648

4. Average power consumption of one years is 17648 kWh (Units) is collected after deducting the Solar generation which approximately generation capacity in between 3000 to 4000 Units per month.



5. Graphically Representation of Electricity Distribution:



Fig: Electricity distribution from June 2023 to July 2024



6. Total requirement of electricity, generation of electricity using renewable energy sources (Jun 2023-Jul 2024):

Renewable Max Unit generation	Renewable energy source	Renewable energy generated and used		
200 kWh/day	50 kW Solar on the grid	3000 to 4000 kWh/Month		

7. Renewable energy generation details:

50 kW capacity Solar on the grid power plant. Total per day generation is around 200 Units (kWh)












Fig: Jan 2023 to Dec 2023 month per day Solar generation graph




Fig: Jan 2024 to Sep 2024 month per day Solar generation graph



Basic Info

Plant Name: Techno NJR create date: 2020-11-08

create user: Techno NJR Time Zone: (UTC+05:30) Chennai,Kolkata,Mumbai,New Delhi

Administrative Area: India Rajasthan Udaipur Udaipur Udaipur Address: Plot-SPL-T, Bhamashah (RIICO) Industrial Area, Kaladwas Udaipur 313003 (Rajasthan) I.

Coordinate: Longitude 73°45'6.79" Latitude 24°31' 3.17"

System Info

Plant Type: Residential Rooftop System Type: All on Grid

Operating Date: 2020-11-08 Azimuth: 180°
Installed Capacity: 50kWp Angle of tilt: 26°

Yield Info

Currency: INR Unit Price: 8.85INR/kWh

Total Cost: 375.00K INR

Fig: Solar Power Plant Profile

8. Conclusion:

In conclusion, data generated in energy audits are useful for understanding the energy distribution and utilization of college. The college needs a maximum of 15731 kWh (Units) per month. On-grid Solar plant generates a maximum of 200 units per day so monthly generation is around 4000 to 6000 kWh (Units).

9. Recommendation:

- Use separate sub energy meter/connection for different locations like hostel, canteen, Mechanical workshop and offices.
- Replace all non-LED Tube lights with LED lights and bulbs, to save more power.
- Replace CRT monitor using LED or LCD monitor.

10. Result and Discussion:

As far as the energy audit, electricity audit is the main concern regarding the educational institutions. We have collected data by considering the tube light, fan, computer, printer, A.C. and instruments. The total requires full load power is 217.855 kW. The energy consumption of two years by all devices is **32844 kWh** per month and On-grid solar renewable sources generate around 3000 to 4000 Units/Month.

